



## BEMAC LABORATORIES

A Division of Mahaffey Associates Pty Ltd. ABN 90 001 629 036

Unit 9/108-110 Percival Rd. (PO Box 2162) Smithfield NSW 2164

Ph (02) 9756 4003 Fax (02) 9757 4228 Email: mahaffey@mahaffey.com.au

**Client:** Hydocon  
**Project:** HydroSTON Quartz  
**Site:** -  
**Test Type:** Efflorescence  
**Test Method:** AS4456.6

**Job Number:** 10759  
**Sampling Date:** Nov 2018  
**Test Date (Commencement):** 13/03/19  
**Observation/Test Date:** 23/03/19  
**Unit Designation/Lot ID:** Block  
**Lot marking/Location:** -  
**Sample ID:** HydroSTON 50 Block  
**Working Size:** 200 x 100 x 50 mm  
**Specimen Dimension:** 200 x 100 x 50 mm  
**Orientation in Bath:** Standing on End

Specimen Number	Efflorescence	
	Type	Classification
1	Amorphous	Slight
2	Amorphous	Slight
3	Amorphous	Slight
4	Amorphous	Slight
5	Amorphous	Slight
Classification of Sample		Slight

  
David Wilmshurst  
Approved Signatory