



BEMAC LABORATORIES

A Division of Mahaffey Associates Pty Ltd. ABN 90 001 629 036


Unit 9/108-110 Percival Rd. (PO Box 2162) Smithfield NSW 2164

Ph (02) 9756 4003 Fax (02) 9757 4228 Email: mahaffey@mahaffey.com.au

Client: HydroCon
Project/Job No: 10759
Material: HydroSTON
Specimens: 50 Flagg 300 x 300 x 50 mm
Test Method: AS/NZS 4586 - 2013: Appendix A - Wet Pendulum Method
Test Type: Slip Resistance of New Pedestrian Surfaces
Slider Material: Rubber Slider: 96(4S)

BEMAC Job No.: 10759
Sampled By: Client
Sampling Date: Jun 2018
Test Date: 20/03/2019
Fixed / Unfixed Fixed
Surface -
Test Location: Lab

Specimen	Slope (Direction of Test)		Temperature (Deg C)	Mean British Pendulum Number	Surface Class
	Deg	%			
1	0	0	26.0	65	
2	0	0	26.0	65	
3	0	0	26.0	65	
4	0	0	26.0	66	
5	0	0	26.0	62	
Means Results for all specimens				65	P5


David Wilmshurst
Approved Signatory